Submittal Data: ASU12RLF1

Job Name:

CFM Cooling - H/M/L/Q

CFM Heating - H/ M/ L/Q

Suction (O.D.)



Purchaser:									
Engineer:									
Submitted To:			For:		Reference		Approval		Construction
Submitted By:									
Unit Designation:	Schedule No.		Model No.:						
Capacities:	Standard Features:								
Voltage/Frequency/Phas	208-230/60/1		Minimum Heat						
Available Voltage Range		187-253VAC			Five year parts warranty				
Cooling		12,000 BTU/h		•					
Outdoor Design Temp. Fo DB/WB 95/75				Digital wireless remote control					
Heating		16,000 BTU/h		•	Auto Louver: Up/Down Apple Catechin / Ion Deodorizing Filters				
Outdoor Design Temperature Fo DB/WB		47/43		•					

Location:

Noise Level Cooling db (A) - H/M/L/Q 43/40/32/21

Noise Level Heating db (A) - H/M/L/Q 43/38/33/22

Weight 24 lbs.

Refrigerant Piping:* Discharge Vapor Line (O.D.) 1/4 in.

- Sleep Timer
- Auto Restart/ Reset
- 24 hour timer
- Quiet Mode
- Dry mode
- Refrigerant R410A

*Piping lengths vary by outdoor unit. See outdoor unit submittal sheet for detailed specifications.

441/376/282/182

441/376/306/194

3/8 in.

OUTLINE AND DIMENSIONS

